



**Notes:**

1. All gas membranes should be inspected and verified in accordance with Table 7 of BS8485:2015.
2. Ensure that any penetration details are sealed as per RIW's requirements. Please contact technical@riw.co.uk or 0134439777 for further assistance.
3. Sheetseal GR to be applied with reinforcing strips, etc.as required.
4. A maintainable sub-soil drain must be provided at the base of the wall as required.
5. Sub-soil drainage should be capable of discharging water away from the structure.